



PSB Singapore

# CERTIFICATE OF CONFORMITY

**No. CLS1B 092417 0001 Rev. 01**

Initial No. CLS1B 092417 0001 Rev. 00

**Certificate Holder:**  
**Teledata Fire Systems (Asia) Pte Ltd**  
252 Jalan Kayu  
Singapore 799478  
SINGAPORE

**Certification Mark:**



TÜV SÜD PSB

**Product:** Fire Alarm Panels  
**Brand Name:** TELEDATA  
**Model(s):** Teledata one  
**Product Details:** Analogue Addressable, 1 - 9 Loop Fire Alarm Panel  
**Standard(s):** BS EN 54-2:1997/A1:2006  
BS EN 54-4:1998/A2:2006  
SS 645:2019 (cl 5.2, 5.3 & 5.5)  
**Country of Origin:** Italy  
**Test Report(s):** 7191231787-EEC20/YKF, 7191194014-EEC18/01-YKF &  
7191194014-EEC18/02-YKF  
EVPÚ a.s. Test Report Nos.: 90028/2014, 90028S/2014 &  
00194E/2014  
**Valid until:** 2024-03-03

Products listed under Class 1B must have TÜV SÜD PSB PLS mark as shown above affixed/printed on them. Failure to comply with this requirement may result in revocation of this certificate.

Page 1 of 1  
**Issued on:** 2020-05-18

Vice-President (Certification Department)  
TÜV SÜD PSB



This Certificate is part of a full Report and should be read in conjunction with it. This Certificate remains the property of TÜV SÜD PSB Pte Ltd and shall be returned upon request. The use of this Certificate is subjected to TÜV SÜD Group Testing and Certification Regulations; TÜV SÜD PSB Pte Ltd (PSB) General Terms and Conditions of Business and PSB Product Listing Scheme (PLS) Application Fact Sheet. The manufacturer is solely responsible for compliance of any product that has the same designation as the product type-tested. Persons relying on this Certificate should verify its validity by checking TÜV SÜD PSB's website at [www.tuv.sud-psb.sg](http://www.tuv.sud-psb.sg)

TÜV SÜD PSB Pte Ltd • 1 Science Park Drive • Singapore 118221

TUV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD  
ZERTIFIKAT ◆ CERTIFICATE ◆ CERTIFICADO ◆ СЕРТИФИКАТ ◆ 證書 ◆ CERTIFICATE ◆