



Certificate of Compliance

This certificate is issued for the following:

Nitrogen Generators
(see attached listing)

Prepared for:

Engineered Corrosion Solutions, LLC
11336 Lackland Rd
St Louis, MO 63146

FM Approvals Class: FM 1035 (December 2014)

Approval Identification: PR459762

Approval Granted: November 5, 2021

To verify the availability of the Approved product, please refer to www.approvalguide.com

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

A handwritten signature in black ink that reads 'D.B. Fuller'.

David Fuller

VP - Manager of Fire Protection
FM Approvals
1151 Boston-Providence Turnpike
Norwood, MA 02062



Member of the FM Global Group





Certificate of Compliance

Model No	Outlet Pipe Connection Size		Sprinkler System Capacity		Bypass Capacity		Remarks
	in	(mm)	gal	(L)	gal	(L)	
AG-675	1/2 MNPT	(15)	675	(2550)	215	(810)	
AG-950	1/2 MNPT	(15)	950	(3600)	265	(1005)	
AG-2000	1/2 MNPT	(15)	2000	(7575)	900	(3405)	
AG-3500	1/2 MNPT	(15)	3200	(12120)	900	(3405)	
AG-6500	1/2 MNPT	(15)	6500	(24600)	1440	(5445)	1
AG-11000	1/2 MNPT	(15)	11000	(41640)	2250	(8520)	2
AG-18500	1/2 MNPT	(15)	18000	(68130)	2250	(8520)	2
AG-22500	1/2 MNPT	(15)	22500	(85170)	2250	(8520)	2

Remarks:

1. Bypass capacity listed is when the unit is supplied with a COMP-5 compressor package. The unit is also FM Approved with other compressor package options.
2. Bypass capacity listed is when the unit is supplied with a COMP-7.5 compressor package. The unit is also FM Approved with other compressor package options.



Member of the FM Global Group